



City of Santa Clara

Building Division
1500 Warburton Ave.
Santa Clara, CA 95050
www.santaclaraca.gov

Building Division: 408-615-2440

Email: Building@santaclaraca.gov

Permit Center: 408-615-2420


Email: PermitCenter@santaclaraca.gov

Automated Inspection Scheduling System: 408-615-2400


2019 CALIFORNIA BUILDING CODE - SECTION 11B-404 GENERAL REQUIREMENTS FOR DOORS AND LANDINGS

❖ GENERAL

- a. Revolving doors, gates and turnstiles shall not be part of an accessible route.
- b. **Width:** 32" clear min. (Opening more than 24" deep shall be 36" clear min.)
- c. **Thresholds:** ½" max height
- d. **Hardware:**
 - Operable parts shall be operable with one hand and shall not require tight grasping, pinching or twisting of wrist.
 - *The CBC references [State Fire Marshall Standard 12-10-2](#) which contains specific requirements for egress door hardware.*
 - Located 34" – 44" above finish floor
- e. **Opening Force:**
 - Interior and Exterior hinged doors, sliding or folding doors: 5 lb. max.
 - Fire doors: 15 lb. max.
- f. **Kick Plate:** Bottom 10" high smooth surface on the push side of door or gate.




DOOR HARDWARE AND MOUNTING HEIGHT



NOTE: DOOR CLEAR WIDTH SHALL BE 36" MIN WHEN D > 24"

HINGED DOOR



NOTE: Provide bumper in pocket to prevent door from fully receding.

SLIDING DOOR



FOLDING DOOR

MINIMUM DOOR CLEAR WIDTH




City of Santa Clara
 Building Division
 1500 Warburton Ave.
 Santa Clara, CA 95050
 www.santaclaraca.gov

Building Division: 408-615-2440
 Email: Building@santaclaraca.gov
 Permit Center: 408-615-2420
 Email: PermitCenter@santaclaraca.gov
 Automated Inspection Scheduling System: 408-615-2400

**2019 CALIFORNIA BUILDING CODE - SECTION 11B-404
 GENERAL REQUIREMENTS FOR DOORS AND LANDINGS**

❖ TYPICAL LOCATION AND INFORMATION FOR DOOR HARDWARE





City of Santa Clara
 Building Division
 1500 Warburton Ave.
 Santa Clara, CA 95050
 www.santaclaraca.gov

Building Division: 408-615-2440
 Email: Building@santaclaraca.gov
 Permit Center: 408-615-2420
 Email: PermitCenter@santaclaraca.gov
 Automated Inspection Scheduling System: 408-615-2400


**2019 CALIFORNIA BUILDING CODE - SECTION 11B-404
 GENERAL REQUIREMENTS FOR DOORS AND LANDINGS**

❖ MANEUVERING CLEARANCE AT SWINGING DOORS AND GATES


TABLE 11B-404.2.4.1
 MANEUVERING CLEARANCES AT MANUAL SWINGING DOORS AND GATES

TYPE OF USE		MINIMUM MANEUVERING CLEARANCE	
Approach direction	Door or gate side	Perpendicular to doorway	Parallel to doorway (beyond latch side unless noted)
From front	Pull	60 inches (1524 mm)	18 inches (457 mm) ⁵
From front	Push	48 inches (1219 mm)	0 inches (0 mm) ¹
From hinge side	Pull	60 inches (1524 mm)	36 inches (914 mm)
From hinge side	Push	44 inches (1118 mm) ²	22 inches (559 mm) ³
From latch side	Pull	60 inches (1524 mm)	24 inches (610 mm)
From latch side	Push	44 inches (1118 mm) ⁴	24 inches (610 mm)


- NOTE:
1. Add 12 inches (305 mm) if closer and latch are provided.
 2. Add 4 inches (102 mm) if closer and latch are provided.
 3. Beyond hinge side.
 4. Add 4 inches (102 mm) if closer is provided.
 5. Add 6 inches (152 mm) at exterior side of exterior doors.




FRONT APPROACH



DOOR LOCATED IN A RECESS OR ALCOVE



HINGE APPROACH



LATCH APPROACH



City of Santa Clara
 Building Division
 1500 Warburton Ave.
 Santa Clara, CA 95050
 www.santaclaraca.gov

Building Division: 408-615-2440
 Email: Building@santaclaraca.gov
 Permit Center: 408-615-2420
 Email: PermitCenter@santaclaraca.gov
 Automated Inspection Scheduling System: 408-615-2400


**2019 CALIFORNIA BUILDING CODE - SECTION 11B-404
 GENERAL REQUIREMENTS FOR DOORS AND LANDINGS**

**❖ MANEUVERING CLEARANCE AT DOORWAY WITHOUT DOORS OR GATES.
 MANUAL SLIDING DOORS AND MANUAL FOLDING DOORS**

**TABLE 11B-404.2.4.2
 MANEUVERING CLEARANCES AT DOORWAYS WITHOUT DOORS OR
 GATES, MANUAL SLIDING DOORS, AND MANUAL FOLDING DOORS**

Approach direction	MINIMUM MANEUVERING CLEARANCE	
	Perpendicular to doorway	Parallel to doorway (beyond stop/latch side unless noted)
From front	48 inches (1219 mm)	0 inches (0 mm)
From side ¹	42 inches (1067 mm)	0 inches (0 mm)
From pocket/hinge side	42 inches (1067 mm)	22 inches (559 mm) ²
From stop/latch side	42 inches (1067 mm)	24 inches (610 mm)

- 1. Doorway with no door only.
- 2. Beyond pocket/hinge side.



**FIGURE 11B-404.2.4.2
 MANEUVERING CLEARANCES AT DOORWAYS WITHOUT DOORS, SLIDING DOORS, GATES, AND FOLDING DOORS**




City of Santa Clara
 Building Division
 1500 Warburton Ave.
 Santa Clara, CA 95050
 www.santaclaraca.gov

Building Division: 408-615-2440
 Email: Building@santaclaraca.gov
 Permit Center: 408-615-2420
 Email: PermitCenter@santaclaraca.gov
 Automated Inspection Scheduling System: 408-615-2400


**2019 CALIFORNIA BUILDING CODE - SECTION 11B-404
 GENERAL REQUIREMENTS FOR DOORS AND LANDINGS**

❖ **POWER-ASSISTED DOORS** (CBC 11B-404.3)


- a. **Control:** Sensing devices, push plates or vertical actuation bars shall be placed on both the interior and exterior sides of the doors (CBC 11B-404.2.9 Exception C).
- b. **Height of Push Plate:** **Two push plates shall be provided at each location.**
 - Low Push Plate: centerline of plate shall be 7"-8" AFF
 - High Push Plate: centerline of plate shall be 30"-44" AFF
- c. **Size of Push Plate:** 4" diameter min OR 4"x4" square plate with International Symbol of Accessibility.
- d. **Maneuvering Clearance:** **Shall comply with Section 11B-404.2.4**



THE MINIMUM CLEAR WIDTH FOR AUTOMATIC DOOR SYSTEMS IN A DOORWAY SHALL PROVIDE A CLEAR, UNOBSTRUCTED OPENING OF 32" WITH ONE LEAF POSITIONED AT AN ANGLE OF 90 DEGREES FROM ITS CLOSED POSITION.



1. EXTERIOR POWERED DOORS SHALL BE CONTROLLED ON BOTH THE INTERIOR AND EXTERIOR SIDES OF THE DOORS BY SENSING DEVICES, PUSH PLATES, VERTICAL ACTUATION BARS OR OTHER SIMILAR OPERATING DEVICES COMPLYING WITH TURNING SPACE, CLEAR FLOOR SPACE, AND REACH RANGES.
2. WHERE PUSH PLATES, VERTICAL ACTUATION BARS OR OTHER SIMILAR OPERATING DEVICES ARE PROVIDED, THEY SHALL BE PLACED IN A CONSPICUOUS LOCATION.
3. SEE CBC AND BHMA STANDARDS FOR ADDITIONAL REQUIREMENTS.



EXAMPLE: EXTERIOR POWERED DOOR