



City of Santa Clara
 Building Division
 1500 Warburton Ave.
 Santa Clara, CA 95050
 www.santaclaraca.gov

Building Division: 408-615-2440
 Email: Building@santaclaraca.gov
 Permit Center: 408-615-2420
 Email: PermitCenter@santaclaraca.gov
 Automated Inspection Scheduling System: 408-615-2400

**2019 CALIFORNIA BUILDING CODE - SECTION 11B-213 & DIVISION 6
 GENERAL REQUIREMENTS FOR TOILET & BATHING FACILITIES**

❖ **General (CBC 11B-213)**

Where toilet and bathing facilities are provided, **EACH** toilet and bathing room shall be accessible to persons with disabilities (comply with Section 11B-603) and shall be on an accessible route connected to accessible entry.

Exception:

1. Where toilet and bathing facilities are provided in buildings without a ramp or elevators above and below the first floor permitted by Section 11B-206.2.3 Exception 1, accessible toilet and bathing facilities shall be provided on a story connected by an accessible route to an accessible entrance.
2. In alterations where it is technically infeasible to comply with Section 11B-603, altering existing toilet or bathing room shall not be required where a single accessible unisex toilet room or bathing room is provided and located in the same area and on the same floor as existing inaccessible toilet or bathing rooms. (CBC 11B-213.2 Exception 1)

Where existing toilet rooms or bathing rooms are not accessible (do not comply with Section 11B-603), directional signs indicating the location of the nearest accessible toilet room or bathing room within the facilities shall be provided (CBC 11B-216.8)

❖ **Unisex Facilities**

When is a unisex toilet room allowed? (CPC 422.2 Exceptions):

1. In occupancies with a total occupant load of 10 or less, including customers and employees.
2. In business and mercantile occupancies with a total occupant load of 50 or less including customers and employees.

Number of required accessible unisex toilet rooms:

1. Where multiple single user toilet rooms are clustered at a single location, 50 percent, but no fewer than one, of the unisex toilet rooms at each cluster shall be accessible. (CBC 11B-213.2 Exception 4)
2. Accessible unisex toilet rooms shall be identified by the International Symbol of Accessibility complying with Section 11B-703.7.2.1 (CBC 11B-216.8).
3. Doors to unisex toilet rooms and bathing rooms shall have privacy latches (CBC 11B-213.2.1)

❖ **Children’s Facilities**


1. Water closets and toilet compartments for children’s use shall comply with Section 11B-604.9

SUGGESTED DIMENSIONS FOR WATER CLOSETS SERVING CHILDREN AGES 3 THROUGH 12			
	Ages 3 and 4	Ages 5 through 8	Ages 9 through 12
Water Closet Centerline	12 inches (305 mm)	12 to 15 inches (305 to 381 mm)	15 to 18 inches (381 to 457 mm)
Toilet Seat Height	11 to 12 inches (279 to 305 mm)	12 to 15 inches (305 to 381 mm)	15 to 17 inches (381 to 432 mm)
Grab Bar Height	18 to 20 inches (457 to 508 mm)	20 to 25 inches (508 to 635 mm)	25 to 27 inches (635 to 686 mm)
Dispenser Height	14 inches (356 mm)	14 to 17 inches (356 to 432 mm)	17 to 19 inches (432 to 483 mm)

2. Grab bars in water closets for children’s use shall be installed in a horizontal position 18” minimum and 27” maximum above the finished floor measured to the top of the gripping surface. (CBC 11B-609)

❖ **Door Mounted Signage: (CBC 11B-216.8 & 11B-703.7.2.6)**

- a. Men: A ¼” thick equilateral triangle with edge 12” long and vertex upward.
- b. Women: A ¼” thick circle and 12” in diameter.
- c. Unisex: A ¼” thick circle and 12” in diameter with a ¼” thick triangle superimpose on the circle




Note:
 1. Signage shall contrast with the door, either light on a dark background or dark on a light background
 2. Pictograms and/or lettering are not required on door-mounted signage

❖ **Wall Signage: (CBC 11B-703.2 to 11B-703.6)**

Information: Raised characters, pictorial symbols with Grade 2 Braille for permanent rooms and space of a building



❖ **SIGN INSTALLATION HEIGHT AND LOCATION (CBC 11B-703.4)**



❖ Accessible Features:

1. Water Closets (CBC 11B-604):

- Location: 17" – 18" from side wall at wheel chair accessible toilet
17" – 19" from side wall in the ambulatory accessible toilet
- Seat Height: 17" – 19"
- Flush Controls: hand operated or automatic, located on open side.
- Flush Control Height: Max. 44" above floor
- Minimum Clear Space around water closet: 60" x 56"
- Maneuvering Space in front of Water Closet: 60" wide x 48" deep

2. Grab bars: (CBC 11B-604.5 & 11B-609)

- Circular section: 1 ¼" – 2" outside diameter
- Non-circular section: Cross section dimension of 2" max and Perimeter dimension of 4" - 4.8"
- Spacing between Wall and Grab bar: 1 ½".
- Height: 33" – 36" above finish floor measured to the top of bar
- Side Wall Grab Bar: 42" min. long with 24" in front of water closet. Located 12" max from rear wall & extend 54" from rear wall.
- Rear Wall Grab Bar: 36" min. long. Extend from centerline of the water closet 12" min on one side and 24" min on the other side.
- L-shaped grab bar meeting dimensional requirements of side wall and rear wall grab bars shall be permitted.
- Strength: Minimum 250 lbs.




FIGURE 11B-604.3.1
SIZE OF CLEARANCE AT WATER CLOSETS





FIGURE 11B-609.2.2
GRAB BAR NON-CIRCULAR CROSS SECTION




FIGURE 11B-604.5.1
SIDE WALL GRAB BAR AT WATER CLOSETS





FIGURE 11B-604.5.2
REAR WALL GRAB BAR AT WATER CLOSETS




PROJECTING OBJECTS

RECESSED OBJECTS

3. Urinals: (CBC 11B-605):


- Clear Space: Minimum 30" x 48" for forward approach.
- Fixture Extension: 13.5" min. from wall.
- Rim Height: 17" max. above floor.
- Flush Control: hand operated or automatic.
- Flush Control Height: Max. 44" above floor.



**FIGURE 11B-605.2
HEIGHT AND DEPTH OF URINALS**

4. Lavatories and Sinks (CBC 11B-606):

- Clear Space: Min. 30" x 48" for forward approach.
- Location: 18" min. from side wall to centerline of the fixture.
- Higher of Rim Height or Counter Surface: 34" max above floor.
- Sink Depth: 19" max.
- Toe Clearance: CBC 11B-306.2
- Knee Clearance: CBC 11B-306.3
- Exposed Pipes Under Sink: Insulated.
- Faucet Control: hand operated or automatic



5. Toilet Paper Dispensers (CBC 11B-604.7):


- Height: Below grab bar, 19" min. above floor.
- Location: 7" min – 9" max in front of water closet
Measured from centerline of dispenser
- Type: Continuous paper flow.

6. Mirrors (CBC 11B-603.3):

- Located above lavatories or countertops:
Minimum 1 with bottom edge 40" max. above floor.
- Other location: bottom edge 35" max. above floor.

7. Lockers (CBC 11B-225.2.1):




- 5% minimum but no fewer than one of each type shall be accessible (comply with Section 11B-811)



**FIGURE 11B-604.7
DISPENSER OUTLET LOCATION**

❖ Single Accommodation Toilets


- **Turning Space:** 60" min. diameter clear circular space (CBC 11B-304.3.1) or T-shaped space per Figure 11B-304.3.2
- **Overlap:** Required clear floor spaces, clearance at fixtures, and turning space shall be permitted to overlap (CBC 11B-603.2.2)
- **Door Swing:** Door in any position may encroach into turning space by 12" max. Door shall not swing into the clear floor space or clearance required for any fixtures unless a 30"x 48" clear space is provided within the room beyond the arc of the door swing. (CBC 11B-603.2.3 Exception 2)



IF A 30"x48" CLEAR FLR SPACE IS PROVIDED OUTSIDE THE ARC OF THE DOOR SWING, THE DOOR CAN SWING INTO THE CLEAR FLR SPACE AND CLEARANCE REQUIRED AT THE FIXTURES

❖ Ambulatory Accessible Compartment (CBC 11B-604.8.2)


- **When Required:** Where the total of 6 or more of the toilet compartments (or the combination urinal and water closets) are provided, at least 5% of the total compartments or combination of fixtures, but no fewer than one shall be ambulatory accessible compartment. (CBC 11B-213.3.1)
- **Size:** depth = 60" min.; width = 35" – 37"
- **Clearance at door:** Shall comply with Section 11B-404, except if the approach is to the latch side of the compartment door, clearance between door side of the compartment to any obstruction shall be 44" minimum.
- **Door:** Self closing with door pull on both sides of the door near the latch. Compartment door can't swing into the minimum required compartment area.
- **Side Grab Bars:** 42" minimum long grab bar with 24" in front of water closet shall be provided on both sides of the compartment. Locate grab bars 12" max from rear wall & extend 54" from rear wall.




11B-604.8.2
AMBULATORY ACCESSIBLE TOILET COMPARTMENT

❖ Wheelchair Accessible Compartments (CBC 11B-604.8.1)

- **Size:** Width = 60" min.; Depth = 56" min for wall hung water closet
59" min for floor mounted water closet
- **Maneuvering Space with Side-opening Door:** see Figure 11B-604.8.1.1.2
Door in side wall shall be 4" maximum from the front partition
- **Maneuvering Space with End-opening Door:** see Figure 11B-604.8.1.1.3
Door in front partition shall be 4" maximum from the side wall or partition farthest from the water closet
- **Door:** Self closing with door pull on both sides of the door near the latch. Door shall not swing into the clear floor space or clearance required for any fixture. Doors may swing into that portion of maneuvering space which does not overlap the clearance required at a water closet.
- **Side Grab Bars:** Provide rear and side grab bars per 11B-604.5 (L-shaped grab bars are permitted)




**FIGURE 11B-604.8.1.1.2
MANEUVERING SPACE WITH SIDE-OPENING DOOR**




**FIGURE 11B-604.8.1.1.3
MANEUVERING SPACE WITH END-OPENING DOOR**

❖ Drinking Fountains (CBC 11B-211, 11B-307 & 11B-602)


1. **Application:** No fewer than two drinking fountains shall be provided per floor. One drinking fountain shall be accessible (comply with Sections 11B-602.1 through 11B-602.6) and one drinking fountain shall be for a standing person (comply with Sections 11B-602.7)
2. **Location:** All drinking fountains shall be either be located completely within alcove, positioned completely between wing walls or otherwise positioned so as not to encroach into pedestrian walk ways.
3. **Alcove Dimension:** 32" minimum wide x 18" minimum deep.
36" minimum wide where the depth exceeds 24".
4. **Clear Floor Space:** Minimum 30" x 48" for forward approach centered at a low drinking fountain.
5. **Knee and Toe Clearance:** CBC 11B-306.2 & 11B-306.3.
6. **Depth:** 18"-19" for wall and post mounted cantilever drinking fountain.
7. **Spout Height:** 36" maximum above floor at low drinking fountain.
38"- 43" above floor at high drinking fountain.
8. **Spout Location:** 15" minimum from supporting wall and 5" maximum from front edge of unit.
9. **Control:** Manually operated system that is front mounted or side mounted and located within 6" from the front edge OR automatic electronically controlled device.



(a) ALCOVE INSTALLATION




(b) NONALCOVE WING WALL INSTALLATION




(c) NONALCOVE SOLID WING WALL INSTALLATION

FIGURES – DRINKING FOUNTAIN



* EQUIPMENT PERMITTED IN SHADED AREA

**SPOUT HEIGHT AND KNEE CLEARANCE
AT DRINKING FOUNTAINS**



**CLEAR FLOOR SPACE
AT DRINKING FOUNTAINS**

FIGURES – DRINKING FOUNTAIN (continued)